
California Environmental Protection Agency

Air Resources Board

Vapor Recovery Equipment Defects List

Adopted: September 23, 2002 Amended: [insert month day, year]



Vapor Recovery Equipment Defects List

Date of Issuance: September 23, 2002

GVR All System	GVR All Systems/any E.O.		
equipment	defects	verification procedure	
(a) system	(1) any equipment defect which is identified in an Executive Order (E.O.) certifying a system pursuant to the Certification Procedures incorporated in Section 94011 of Title 17, California Code of Regulations	as set forth in the applicable E.O.	
	(2) absence, improper installation, or disconnection of any component required to be used in the E.O.(s) that certified the system	direct observation	
	(3) installation or use of any uncertified component	direct observation	
	(4) dispensing rate greater than ten (10.0) gallons per minute (gpm) or less than the greater of five (5.0) gpm or the limit stated in the E.O. measured at maximum fuel dispensing	when determined as part of any ARB approved test method or direct measurement for 6030 seconds minimum	
nozzles	(5) phase I vapor poppet inoperative	direct observation	
(b) nozzles	(1) nozzle automatic liquid shutoff mechanisms which malfunction in any manner	EPO No. 26-F-1/direct observation	

Each defect in the tables in this list has a specific alphanumeric identification. Every identification has three parts: i) the executive order number for the table on which the defect appears (or GVR-general vapor recovery-for this "All Systems/any E.O." page only), ii) a sequential letter for the equipment, with which the defect is associated, and iii) a sequential number for the defect itself. As the "equipment" column in the table changes, the defect number sequence that is associated with the specific equipment begins again with one ("(1)"). The same is true for the equipment letter. At the start of a new table, the first identifying letter associated with the first equipment listed will be an "a", the second a "b", and so on. The Executive Order number (part i) is comprised of the characters which proceed the literal description of the system.

For example: the identification for the defect above which is written "installation or use of any uncertified component" is "GVR(a)(3)" and the last defect on the next table (page 2) is "G-70-7(d)(1)".

G-70-7 series Hasstech VCP-2 and VCP-2A				
equipment	defects	verification procedure		
(a) system	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation		
	(2) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent		
	(3) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent		
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent		
	defective vapor valve	GDF-01/GDF-03		
(b) hoses	(1) any coaxial hose with a perforation exceeding one-eighth (0.13) inch diameter	direct measurement/ observation		
	(2) any coaxial hose with slits or tears in excess of one-fourth (0.25) inch in length	direct measurement/ observation		
(c) processing unit	(1) three consecutive unsuccessful attempts to ignite the incinerator which occur at least two hours after a bulk delivery_*	direct measurement/ observation/system monitor observation		
	(2) unit does not activate when the system pressure reaches or exceeds two (2.0) inches water column and occurs at least two hours after a bulk delivery_*	direct measurement using storage tank pressure device		
	(3) emissions which exceed Ringelmann one-half (½) or ten percent (10%) opacity and not attributable to a bulk delivery_*	Method 9		
	(4) vapor processing unit inoperative *	direct observation		
(d) collection unit	(1) vacuum producing device inoperative_*	direct observation		

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-14 series Red Jacket		G-70-17 series Emco Wheaton	G-70-23 series	
	Atlantic Richfield	G-70-33 series Hirt	G-70-36 series OPW	
G-70-38 series Texaco		G-70-48 series Mobil	G-70-49 series Union	
G-70-52 series l	Red Jacket, Hirt	G-70-53 series Chevron	G-70-78 series I	EZ-flow rebuilds
G-70-107 series	Rainbow rebuilds	G-70-125 series Husky Model V G-70-127 series		OPW 111V
G-70-134 series	EZ-flow rebuilds	G-70-139 series Hirt	G-70-170 series EZ-flow rebuilds	
equipment	defects			verification procedure
(a) nozzles	triangular-shaped o	3		direct measurement/ observation
	balance nozzles ar systems, damage s	r flexible cone damaged in the following mad for nozzles for aspirator and eductor as such that the capability to achieve a seal of for one-fourth (0.25%) of the circumferented)	sist type vith a fill pipe	direct measurement/ observation
		maged in the following manner: for boote type systems, more than one-fourth (0.259		direct measurement/ observation
	(4) insertion interlo	ck mechanism which will allow dispensing essed	when the	direct observation/ GDF-09
(b) hoses	(1) any coaxial bala	ance hose with 100 ml or more liquid in th	e vapor path	direct measurement
	(2) any hose with a	visible opening		direct observation
(c) processing unit	(1) vapor processir	g unit inoperative *		direct observation
(d) vapor return lines		nrough the vapor path exceeds by a facto fied in the Executive Order(s) that certified		TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

The identification scheme for defects listed in this table is the same three part alphanumeric identification (see page 1) as the other tables. However, the correct executive order number will be the one for the specific system in question. For example: the identification for the defect above which is written "any hose with a visible opening" will begin "G-70-" and end with "(b)(2)." On the Atlantic Richfield system it will be "G-70-25(b)(2)", on the Texaco system it will be "G-70-38(b)(2)", and so on.

G-70-118 series Amoco V-1			
equipment	defects	verification procedure	
(a) system	(1) defective vapor valve	GDF-01/GDF-03 <u>2</u>	
	(2) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent	
	(3) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation	
	(4) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent	
	(5) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent	
(b) Husky V-1 nozzle	(1) efficiency compliance device (ECD) damaged such that at least one eighth (0.13%) of the diameter is missing	direct measurement/ observation	
	(2) less than two unblocked vapor holes	direct observation	
(c) OPW 11-VAA nozzle	(1) any ECD damaged such that a slit from the outer to inner edge exists	direct measurement/ observation	
	(2) less than three unblocked vapor holes	direct observation	

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

	Marconi (Gilbarco)Vapor Vac	
equipment	defects	verification procedure
(<u>a</u>) system	(1) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	defective vapor valve	GDF-01/GDF-03
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) both booted and unbooted nozzle types connected to the same vapor pump	direct observation
	(5) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
(b) Catlow ICVN nozzle	(1) less than three unblocked vapor holes	direct observation
HOZZIO	(2) defective vapor valve	GDF-01/GDF-02
	(3) efficiency compliance device slit from base to the rim	direct observation
(c) Emco Wheaton A4505	(1) less than three unblocked vapor holes	direct observation
nozzle	(2) defective vapor valve	GDF-01/GDF-02
	(3) one-eighth (0.13%) of vapor guard circumference missing	direct measurement/ observation
(d) Emco Wheaton A4500 nozzle	(1) less than three unblocked vapor holes	direct observation
(<u>e</u>) Husky V34 6250 nozzle	(1) a one and one-half (1.5) inch or greater slit in vapor splash guard	direct measurement/ observation
	(2) any hole greater than three-eighths (0.38) inch in vapor splash guard	direct measurement/ observation
	(3) defective vapor valve	GDF-01/GDF-02
(f) Husky V3 6201 nozzle	(1) all vapor holes blocked	direct observation
(g) OPW 11VAI nozzle	(1) less than four unblocked vapor holes	direct observation
(h) OPW12VW nozzle	(1) all vapor holes blocked	direct observation
HUZZIG	(2) defective vapor valve	GDF-01/GDF-02
	(3) vapor escape guard with three-fourths (0.75%) of the circumference missing	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-153 series Dresser/Wa		
equipment	defects	verification procedure
(a) system	(1) any splash guard that interferes with the operation of a vapor escape guard (VEG) or vapor splash guard (VSG) unit	direct measurement/ observation
	(2) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(3) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(4) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(5) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic foot feet per hour (60 SCFH)	TP201.4 or equivalent
	(6) defective vapor valve	GDF-01/GDF-032
(b) OPW 11VAI and Husky V34 6200-4 nozzles	(1) less than two unblocked vapor holes	direct observation
V34 0200-4 11022165	(2) any VEG damaged such that at least one-eighth (0.13%) of the circumference is missing	direct measurement/ observation
(c) Husky V34 6200 nozzle	(1) less than two unblocked vapor holes	direct observation
(d) Husky V34 6200 and V34 6250 nozzles	(1) any VSG damaged such that at least a one and one-half (1.5) inch slit has developed	direct measurement/ observation
	(2) any VSG flange portion that does not make contact with or cover the entire fill-pipe opening	direct measurement/ observation
	(3) any VSG with a hole greater than three-eighths (0.38) inch	direct measurement/ observation
(e) Emco Wheaton A4505 nozzle	(1) less than three unblocked vapor holes	direct observation
HOZZIE	(2) any vapor guard (VG) damaged such that at least one-eighth (0.13%) of the circumference is missing	direct measurement/ observation
(f) Catlow ICVN and Richards Astrovac nozzles	(1) less than three unblocked vapor holes	direct observation
1.10.10100 / 1010000 11022100	(2) any efficiency compliance device damaged with a slit from the base to the rim	direct observation
(g) OPW 12VW nozzle	(1) all vapor holes blocked	direct observation
	(2) any VEG damaged such that at least three-quarters (0.75%) of the circumference is missing	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-154 series Tokheim	G-70-154 series Tokheim MaxVac				
equipment	defects	verification procedure			
(a) nozzles	(1) defective vapor valve	GDF-01/GDF-03 <u>2</u>			
(b) OPW 11VAI and Husky V34 6200-5 nozzles	(1) efficiency compliance device (ECD) damaged such that at least one-fourth (0.25%) of the circumference is missing	direct measurement/ observation			
(c) Husky V34 6200 and V34 6250 nozzles	(1) less than two unblocked vapor holes	direct observation			
and volidated notation	(2) vapor splash guard (VSG) damaged such that at least a one and one-half (1.5) inch slit has developed	direct measurement/ observation			
	(3) VSG damaged such that greater than a three-eighths (0.38) inch hole has developed	direct measurement/ observation			
(d) Emco Wheaton A4505	(1) less than seven unblocked vapor holes	direct observation			
(e) Catlow ICVN and Richards Astrovac	(1) less than four unblocked vapor holes	direct observation			
Triolidiae 7 en evae	(2) any nozzle with an ECD damaged with at least one-fourth (0-25%) of the circumference missing	direct measurement/ observation			
(<u>f</u>) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent			
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation			
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent			
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic foot feet per hour (60 SCFH)	TP201.4 or equivalent			

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-159 series Saber nozzle for Gilbarco (Marconi) Vapor Vac and WayneVac		
equipment	defects	verification procedure
(a) nozzles	(1) a fill guard damaged such that at least one-fourth (0-25%) of the outer edge of the guard is missing	direct measurement/ observation
	(2) less than four unblocked vapor holes on the Gilbarco (Marconi) systems	direct observation
	(3) less than two unblocked vapor holes on the WayneVac systems	direct observation
	(4) defective vapor valve on the WayneVac systems	GDF-01/GDF-03 <u>2</u>
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-163 series OPW Vapor EZ			
Equipment	defects	verification procedure	
(a) nozzles	(1) efficiency compliance device damaged such that at least one-eighth (0-13%) of the diameter is missing	direct measurement/ observation	
	(2) less than three unblocked vapor holes	direct observation	
	(3) defective vapor valve	GDF-01/GDF-032	
(<u>b</u>) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent	
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation	
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent	
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic feet per hour (60 SCFH)	TP201.4 or equivalent	

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-164 series Hasstech		T
equipment	defects	verification procedure
(a) system	defective vapor valve	GDF-01/GDF-03
	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(2) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(3) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
(b) OPW 11VAI steel spout	(1) less than six unblocked vapor collection holes	direct observation
Spout	(2) defective vapor valve	GDF-01/GDF-02
(c) OPW 11VAI aluminum spout	(1) less than four unblocked vapor collection holes	direct observation
Spoul.	(2) defective vapor valve	GDF-01/GDF-02
(d) Husky V3 6201 nozzle	(1) all vapor collection holes blocked	direct observation
(e) Husky V34 6200-8 nozzle	(1) all vapor collection holes blocked	direct observation
	(2) defective vapor valve	GDF-01/GDF-02
(f) Emco Wheaton A4500 nozzle	(1) any visible puncture or tear of the vapor guard/vapor seal assembly	direct observation
	(2) less than three unblocked vapor collection holes	direct observation
(g) collection unit	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) dispensing when the collection unit is disabled *	direct observation/ system monitor observation
	(3) normal operating level at the inlet of the collection unit less than thirty (30) inches water column vacuum_*	direct measurement/ observation
(h) processing unit	(1) emissions which exceed Ringelmann one-half (½) or ten percent (10%) opacity and not attributable to a bulk delivery *	Method 9
	(2) twenty (20) consecutive unsuccessful attempts to ignite the process unit_*	direct measurement/ observation/system monitor observation
	(3) dispensing when the process unit is disabled*	direct measurement/ observation/system monitor observation
	(4) processing unit inoperative *	direct observation
(i) ECS-1 electronic control and status panel	(1) ratio of process unit/solenoid valve time less than nine tenths (0.90)*	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

Page 9 of 192021

G-70-165 se	ries Healy Model 600	
equipment	defects	verification procedure
(a) nozzles	(1) any nozzle with a vapor guard <u>missing</u> , damaged such that a slit from the outer edge of the open end flange to the spout anchor clamp, <u>or which has equivalent cumulative damage</u>	direct observation
	(2) any nozzle which has fewer than four unblocked vapor collection holes	direct observation
	(3) defective vapor valve	GDF-01/GDF-032 EO G-70-183 Exhibit 2 vapor valve test or equivalent
	(4) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(5) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
(b) system	(1) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic foot feet per hour (60 SCFH)	TP201.4 or equivalent
(c) central vacuum unit	(1) dispensing when the central vacuum unit is disabled *	direct measurement/ observation/system monitor observation
	(2) vacuum level outside of the range specified in G-70-165 for more than fifteen (15) seconds (Approval Letter 97-20), measured while dispensing is occurring.*	direct measurement/ observation/system monitor observation
	(3) product dispensed when the vapor return line valve is closed	direct measurement/ observation/TP201.5

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-169 se	G-70-169 series Franklin Electric Intellivac			
equipment	defects	verification procedure		
(a) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent		
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation		
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent		
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent		
	(5) defective vapor valve	GDF-01/GDF-03 <u>2</u>		
(b) OPW 11VAI nozzle	(1) efficiency compliance device damaged such that at least one-fourth (0.25%) of the circumference is missing	direct measurement/ observation		
	(2) fewer than two unblocked vapor collection holes	direct observation		
(c) Husky V34 6250 nozzle	(1) any nozzle with a vapor splash guard (VSG) damaged such that at least one and one-half (1.5) inch slit has developed	direct measurement		
	(2) any VSG damaged such that greater than a three-eighths (0.38) inch hole has developed	direct measurement		

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-175 series Hasstech VC	P-3A	
equipment	defects	verification procedure
(a) system	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(2) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(3) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
(b) OPW 11VAI steel spout	(1) less than six unblocked vapor collection holes	direct observation
(c) OPW 11VAI aluminum spout	(1) less than four unblocked vapor collection holes	direct observation
(d) Emco Wheaton A4500	(1) fewer than three unblocked vapor collection holes	direct observation
HOZZIC	(2) any visible puncture or tear of the vapor guard/vapor seal assembly	direct observation
(e) Husky V3 6201 nozzle	(1) all vapor collection holes blocked	direct observation
(<u>f</u>) Husky V34 6200-8	(1) all vapor collection holes blocked	direct observation
dispenser	(2) defective vapor valve	GDF-01/GDF-032
(g) collection unit	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) dispensing when the collection unit is disabled_*	direct observation/ system monitor observation
	(3) normal operating level at the inlet of the collection unit less than thirty (30) inches water column vacuum *	direct measurement/ observation
(h) processing unit	(1) twenty (20) consecutive unsuccessful attempts to ignite the processing unit *	direct_measurement/ observation/ system monitor observation
	(2) emissions which exceed Ringelmann one-half (½) or ten percent (10%) opacity and not attributable to a bulk delivery_*	Method 9
	(3) dispensing when the processing unit is disabled*	direct measurement/ observation/system monitor observation
	(4) processing unit inoperative *	direct observation
(i) ECS-1 electronic control and status panel	(1) ratio of process unit/solenoid valve time less than nine tenths (0.90) *	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-177 series Hirt VCS400-7			
equipment	defects	verification procedure	
(a) system	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation	
	(2) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent	
	(3) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent	
	(4) processing unit inoperative *	direct observation	
(b) OPW 11VA-29 nozzle	(1) defective vapor valve	GDF-01/GDF-032	
1111120	(2) less than five unblocked vapor collection holes	direct observation	
(c) hoses	(1) any visible puncture or tear equivalent to a diameter of 0.136 inches or greater	direct measurement/ observation	

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-179 series Catlow ICVN-VI		
equipment	defects	verification procedure
(a) nozzles	(1) efficiency compliance device damaged such that at least three-fourths (0.75%) of the diameter is missing	direct measurement/ observation
	(2) any nozzle which has less than four unblocked vapor collection holes	direct observation
	(3) defective vapor valve	GDF-01/GDF-03 <u>2</u>
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-181 series Hirt VCS400-7 AGT		
<u>equipment</u>	defects	verification procedure
(a) system	(1) any fueling point associated with a vapor line disconnected and open	direct observation
	to the atmosphere, including all fueling points at the facility if vapor lines	
	are manifolded	
	(2) pressure drop through the system exceeds one-half (0.50) inch water	TP201.4 or equivalent
	column at sixty cubic feet per hour (60 CFH)	
	(3) any grade of a fueling point not capable of demonstrating an air to	TP201.5 or equivalent
	liquid ratio compliance with its performance standard	
	(4) processing unit inoperative *	direct observation
(b) OPW 11VA-29 nozzle	(1) defective vapor valve	GDF-01/GDF-02
11 VA 23 1102218	(2) less than five unblocked vapor collection holes	direct observation
(c) hoses	(1) any visible puncture or tear equivalent to a diameter of 0.136 inches	direct measurement/
	<u>or greater</u>	observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-183 se	ries Healy/Franklin Vac Assist	
equipment	defects	Verification procedure
(a) nozzles	(1) a vapor guard damaged such that a slit exists from the outer edge of the open end flange to the spout anchor clamp	direct observation
	(2) any nozzle which has less than four unblocked vapor collection holes	direct observation
	(3) defective vapor valve	GDF-01/GDF-032 EO G-70-183 Exhibit 2 vapor valve test or equivalent
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-186 se	ries Healy Model 400 ORVR	
equipment	defects	verification procedure
(a) nozzles	(1) any operating pressure range at the nozzle boot/fill-pipe interface less than one-half (0.50) inch water column vacuum or greater than one-fourth (0.25) inch water column pressure	EO G-70-186 Exhibit 5 test
	(2) defective vapor valve	GDF 01/GDF 032 EO G-70-191 Exhibit 2 vapor valve test or equivalent
system	system not operating within the vacuum level range as per G-70-186	direct measurement/ observation/system monitor observation
(b) central vacuum unit	(1) product dispensed when the central vacuum unit is inoperative or disabled *	direct measurement/ observation/TP201.5 or equivalent system monitor observation
	(2) system does not achieve an operating vacuum of sixty-five (65) inches water column for three consecutive dispensings under normal operating conditions *	direct measurement/ observation/system monitor observation
	(3) system operates at a vacuum less than sixty-five (65) inches water column over a one hour period *	direct measurement/ observation/system monitor observation
	(4) vacuum level dropping below sixty (60) inches water column for more than three seconds after the system has reached sixty-five (65) inches water column, while dispensing is occurring *	direct measurement/ observation/system monitor observation
	(5) vacuum level above ninety (90) inches water column while dispensing is occurring *	direct measurement/ observation/system monitor observation
	(6) product dispensing when the non-restrictive ball valve installed in the vapor return line is closed *	direct measurement/ observation
(c) system	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(2) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(3) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
	(4) any venting through system monitor vent in excess of ten hours in any calendar day not attributable to a Phase I fuel delivery *	observation/system monitor observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-187 series Healy Model 400 ORVR AGT (AST)			
equipment	defects:	verification procedure	
(a) nozzles	(1) any operating pressure range at the nozzle boot/fill-pipe interface less than one-half (0.50) inch water column vacuum or greater than one-fourth (0.25) inch water column pressure	EO G-70-187 Exhibit 5 test	
	(2) defective vapor valve	GDF 01/GDF 02 EO G-70-191 Exhibit 2 vapor valve test or equivalent	
	(3) any nozzle boot with a concatenation of all tears greater than one-half (0.50) inch in length	direct measurement/ observation	
(b) central vacuum unit	system vacuum less than sixty-five (65) inches or greater than eighty-five (85) inches water	direct measurement/ observation	
	(1) product dispensed when the central vacuum unit is inoperative or disabled *	direct measurement/ observation/TP201.5 or equivalent system monitor observation	
	system does not achieve an operating vacuum of sixty-five (65) inches water column within fifteen (15) seconds after the system is energized	direct measurement/ observation	
	(2) system does not achieve an operating vacuum of sixty-five (65) inches water column for three consecutive dispensing episodes *	direct measurement/ observation/system monitor observation	
	(3) system does not achieve an operating vacuum of sixty-five (65) inches water column within a one hour period for any single dispensing episode*	direct measurement/ observation/system monitor observation	
	(4) vacuum level dropping below sixty (60) inches water column for more than three seconds after the system has reached sixty-five (65) inches water column, while dispensing is occurring *	direct measurement/ observation/system monitor observation	
	(5) vacuum level above ninety (90) inches water column while dispensing is occurring	direct measurement/ observation/system monitor observation	
	$(\underline{6})$ product dispensing when the non-restrictive ball valve installed in the vapor return line is closed $\underline{^*}$	direct measurement/ observation	
(c) system	(1) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation	
	(2) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent	
	(3) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent	
Phase II system	(4) any venting through system monitor vent in excess of ten hours in any calendar day not attributable to a Phase I fuel delivery*	direct measurement/ observation/system monitor observation	

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-188 series Catlow ICVN w/Gilbarco (Marconi) VaporVac System		
equipment	defects	verification procedure
(a) nozzles	(1) ECD damaged such that at least three-fourths (0.75%) of the diameter is missing	direct measurement/ observation
	(2) defective vapor valve	GDF-01/GDF-03 <u>2</u>
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-191 series Healy ORVR		
equipment	defects	verification procedure
(a) nozzles	(1) any nozzle with a vapor collection boot which has one-half (0.50%) of the mini-boot faceplate or greater missing	direct measurement/ observation
	(2) defective vapor valve	GDF 01/GDF 032 EO G-70-191 Exhibit 2 vapor valve test or equivalent
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-193 series Hill-Vac		
equipment	defects	verification procedure
(a) system	(1) fillpipe gauge pressure less than negative one (-1.0) inch or greater than two (2.0) inches water column	direct measurement/ observation
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) pressure drop through the system exceeds one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
(b) nozzles	(1) a boot with any tear exceeding one-half (0.50) inch	direct measurement/ observation
	(2) faceplate damage such that the fillpipe interface is adversely affected for twenty-five percent (25%) or more of the circumference of the faceplate	direct measurement/ observation
(c) jet pump	(1) dispensing of gasoline when either jet pump is disabled	direct observation
	(2) failure to achieve operating vacuum of thirty-five (35) inches water column within five seconds after the system is activated, for three consecutive dispensing episodes	direct measurement/ observation
	(3) a vacuum level below fifteen (15) inches water column for more than three seconds after the system has reached thirty-five (35) inches water column while dispensing	direct measurement/ observation
	(4) a vacuum level above eighty-five (85) inches water column measured while dispensing to non-ORVR vehicles	direct measurement/ observation
	(5) product dispensing when any ball valve installed at the vapor return line connection to each Healy Model 100 jet pump is closed	direct measurement/ observation
(d) Liquid drop out pot	(1) opening drain valve at anytime other than when repair operations are underway	direct observation
	(2) product dispensing when any ball valve installed at the liquid drop pot in the liquid removal line is closed	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-196 series SaberVac		
equipment	Defects	verification procedure
(a) Husky 605104 nozzle	(1) vapor splash guard (VSG) with a one and one-half (1.5) inch or larger slit	Direct measurement/ observation
HOZZIE	(2) VSG with a three-sixteenths (0.19) inch or larger hole	Direct measurement/ observation
	(3) the VSG flange portion doesn't make contact with entire fillpipe opening	direct observation
	(4) defective vapor valve	GDF-01/GDF-032
(b) system	(1) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard as described in G-70-196	as described in G-70-196
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) underground storage tank gauge pressure greater than two inches water column over an extended period as defined by E.O. G-70-196 Exhibit 2*	direct measurement/ observation
	(5) pressure drop through system exceeding one-half (0.50) inch water column at sixty standard cubic footfeet per hour (60 SCFH)	TP201.4 or equivalent
	(6) dispensing of product from any fueling point associated with a disconnected vapor line	direct measurement/ observation

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

G-70-204 series Gilbarco Vapor Vac/OPW Vaporsaver		
equipment	defects	verification procedure
(a) system	(1) pressure drop through the system exceeds one-half (0.50) inch water column at sixty cubic feet per hour (60 CFH)	TP201.4 or equivalent
	(2) any fueling point associated with a vapor line disconnected and open to the atmosphere, including all fueling points at the facility if vapor lines are manifolded	direct observation
	(3) system not in compliance with the static pressure decay test criteria *	TP201.3 or equivalent
	(4) any grade of a fueling point not capable of demonstrating an air to liquid ratio compliance with its performance standard	TP201.5 or equivalent
	(5) defective vapor valve	GDF-01/GDF-02
(b) Catlow ICVN nozzle	(1) less than three unblocked vapor holes	direct observation
<u>IIOZZIC</u>	(2) efficiency compliance device slit from base to the rim	direct observation
(c) Emco Wheaton A4505	(1) less than three unblocked vapor holes	direct observation
nozzle	(2) one-eighth (1/8) of vapor guard circumference missing or equivalent cumulative damage	direct measurement/ observation
(d) Husky V34 6250 nozzle	(1) a one and one-half (1.5) inch or greater slit in vapor splash guard or equivalent cumulative damage	direct measurement/ observation
	(2) any hole greater than three-eighths (3/8) inch in vapor splash guard or equivalent cumulative damage	direct measurement/ observation
(e) OPW12VW nozzle	(1) all vapor holes blocked	direct observation
HOLLIN	(2) vapor escape guard with three-fourths (3/4) of the circumference missing or equivalent cumulative damage	direct measurement/ observation
<u>(f) vapor</u> processor	(1) vapor processor inoperative *	direct observation/ G-70-204 Exhibit 2

^{*} When the identified defect is detected in the listed equipment, the defect determination applies to all affected interrelated systems (which may include all systems at the motor vehicle fueling operation).

Defect Identification Methods Used In the Verification Procedure Column

- 1. TP201.5: Determination (by Volume Meter) of Air to Liquid (A/L) Volume Ratio of Vapor Recovery Systems of Dispensing Facilities, Adopted April 12, 1996 2. TP201.4: Determination of Dynamic Pressure Performance of Vapor Recovery Systems of Dispensing Facilities 3. TP201.3: Determination of Two-Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities 4. GDF-01: Bag Test for Multi-Nozzle Vacuum Assist Systems 5. GDF-03: Pressure Integrity Performance Verification for Vacuum Assist Systems [Squeeze Bulb Test] 65. Method 9: 40 Code Federal Regulations Part 60 Appendix A: Reference Method 9/ EPA Section 3.12 Visible Determination of the Opacity of Emissions from
- 76. G-70-186-187 Exhibit 5: Fillneck Vapor Pressure Regulation Fueling Test
- 87. EPO No. 26-F-1: Vapor Recovery Systems Field Compliance Testing
- 98. Storage Tank Pressure Device: described and shown in TSD Appendix 6
- 9. GDF-02: Bag Test for Single-Nozzle Vacuum Assist Systems

Stationary Sources

10. GDF-09: Phase II Balance System Nozzle Insertion Interlock Operation Determination

Page 21 of 192021