



Winston H. Hickox
Agency Secretary

Air Resources Board

Alan C. Lloyd, Ph.D.
Chairman

1001 I Street • P.O. Box 2815 • Sacramento, California 95812 • www.arb.ca.gov



Gray Davis
Governor

April 2, 2003

03-03

Mr. Carl Griffin
General Manager
Healy Systems, Inc.
17 Hampshire Drive
Hudson, New Hampshire 03051

Dear Mr. Griffin:

You requested California Air Resources Board (ARB) certification of the Model 807 Swivel Breakaway and the 75B-XXX-S4S2 and 75B-XXX-S4F2 Hose assemblies with Balance Adaptor for use on all currently certified Healy Systems, Inc. Executive Orders for vapor recovery systems.

These components have been installed at a test site for an operational test and remain at the test site through the date of this letter. There have been breakaway disconnects due to vehicle drive off that have required reconnection, and each fueling point is still performing with no measured degradation in performance.

As required by ARB certification procedures, you provided the approvals of the Department of Industrial Relations, Division of Occupational Safety and Health, the Department of Forestry and Fire Protection, Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards.

We have determined that these components have passed the operational and applicable performance tests and have not compromised the performance of the system. Therefore, the Healy components designated by the following part numbers are hereby certified for use on all Healy Systems currently certified under **pre-EVR** Executive Orders G-70-165, G-70-183-AA, G-70-186, and G-70-191-AA:

807 Swivel Breakaway
75B-XXX-S4S2 Hose assembly w/ Balance Adaptor
75B-XXX-S4F2 Hose assembly w/ Balance Adaptor

The XXX designation represents that these hose assemblies can be sold in variable lengths, provided that the maximum length does not exceed the criteria established in any of Healy Systems, Inc. Executive Orders.

The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our Website: <http://www.arb.ca.gov>.


California Environmental Protection Agency

Mr. Carl Griffin
April 2, 2003
Page 2

Healy Systems, Inc., will receive EVR certification for these components only after they have been installed as part of a Phase II EVR certification and successfully pass all required tests.

If you have questions regarding this approval, please contact Paul Marzilli at (916) 445-7431 or via email at pmarzill@arb.ca.gov or Laura McKinney at (916) 322-2496 or via email at lmckinne@arb.ca.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "William V. Loscutoff". The signature is written in a cursive style with a large, prominent "W" and "L".

William V. Loscutoff, Chief
Monitoring and Laboratory Division

cc: Teresa Sewell
Monterey Bay Unified AQMD

Ben Shaw
South Coast AQMD