

Modification Highlights for Executive Order VR-102-P

NOTE: Global change for Executive Order and Installation, Operation, and Maintenance Manual; changed revision letter from O to P.

Part I: Executive Order

Legal Language:

- Added request from OPW to include an alternate pressure/vacuum vent valve.
- Added request from OPW to include an alternate series spill container.
- Added request from OPW to include an alternate multiport configuration.
- Added request from OPW to include color options for spill container covers.
- Added a below-grade vaulted tank configuration as an alternate Phase I system configuration.
- Added Exhibit 5, showing the alternate below-grade vaulted tank Phase I system configuration.

Exhibit 1:

- Added "OPW 723V" to the pressure/vacuum vent valve list.
- Added "-G" to end of part number series for 1-2100, 1-3100, and 1-2200.
- Added "G Color (varies)" to 1-Series Legend.
- Added "4 (alternate sensor)" to 1-Series Legend under U.
- Added new headers for P-Series buckets "Multiport Spill Container OPW P-Series (GAS/E85)" and "P-Series Legend." These include P500 and P700 spill containers.
- Changed "Double Fill" to "Multiport."
- Added emergency vent for below-grade vaulted tank Phase I configuration.
- Added picture of the OPW 723V P/V vent valve.
- Added picture of a multiport spill container.

Exhibit 2:

- Added the 723V PV vent valve to Table 2-1.

Exhibit 5:

- Added Exhibit 5, showing the alternate below-grade vaulted tank Phase I system configuration.

Part II: ARB Approved Installation, Operation, and Maintenance Manual (IOM)

Table of Contents

- Changed heading for "Double Fill" to "Multi-port."
- Added new heading for "Fibrelite Multi-port."
- Added "OPW 723V" to P/V vent valve list.

Summary of Guidelines for Maintenance Activities Required

- Added OPW 723V PV vent valve.
- Added annual static torque test TP-201.1B for product and vapor adaptors.

IOM

- Added new IOM for Fibrelite Multi-port.
- Added new IOM for 723V PV vent valve.